



880 Harrison Street, SE • P.O. Box 4000 • Leesburg, Virginia 20177-1403 • www.lcsa.org

September 13, 2007



Mr. Marchant Schneider
Department of Planning
1 Harrison Street, S.E.
P. O. Box 7000
Leesburg, Virginia 20177-7000

Re: SPEX-2007-0021, Route 50 Medical Campus

Dear Mr. Schneider:

The Sanitation Authority has reviewed the referenced Special Exception Application. The Authority could provide public water and sanitary sewer service to this site through extension to existing facilities. The following comments are offered for your use:

1. Show proposed extension of 24-inch water main, and associated easement along Route 50.
2. A 16" water main extension may be required along Gum Spring Road/Future Road B.

Public water and sanitary sewer service would be contingent upon the developer's compliance with the Authority's Statement of Policy; Rates, Rules, and Regulations; and Design Standards. Should you have any questions, please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink that reads "Paul D. Bodkin". The signature is written in a cursive, flowing style.

Paul D. Bodkin
Project Engineer

PDB:jma

L:\Land Development Programs\Referrals\SPEX2007\07-0021.doc

Dale C. Hammes, P.E.
General Manager/Treasurer

Richard C. Thoesen, P.E.
Deputy General Manager

Administration 703-771-1095 • Metro 703-478-8016 • Fax 703-777-9223 • Customer Service 703-771-1092 • Metro 703-478-8677 • Fax 703-771-4141